



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802
Corvallis, OR Microbiology/Chemistry (d)
540 SW Third Street - Corvallis, OR 97333 - 541.753.4946
Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



Page 1 of 3

LEAD & COPPER RULE REPORT

Client Name: Woodburn School District
1390 Meridian Drive
Woodburn, OR 97071

Reference Number: **17-14192**

Project: WES

System Name:
System ID Number:
DWP Source Number:
Multiple Sources:
Sample Type:
Sample Purpose: Investigative or Other
County:

Analyst: bj
Date Received: 6/15/2017
Report Date: 7/6/2017
Approved By: anp
Authorized by:


Thanh B Phan
Lab Manager, Portland

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
17_32702	6/14/2017	WE1 - Staff R	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.029	mg/L	1.3	0.005	200.8	4072	
17_32703	6/14/2017	WE2 - Office	1030	LEAD	0.008	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.037	mg/L	1.3	0.005	200.8	4072	
17_32704	6/14/2017	WE3 - W. Hall	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.009	mg/L	1.3	0.005	200.8	4072	
17_32705	6/14/2017	WE4 - RM 4	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.037	mg/L	1.3	0.005	200.8	4072	
17_32706	6/14/2017	WE5 - E Hall	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.014	mg/L	1.3	0.005	200.8	4072	
17_32707	6/14/2017	WE6 - RM 11	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.007	mg/L	1.3	0.005	200.8	4072	
17_32708	6/14/2017	WE7 - RM 12	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.007	mg/L	1.3	0.005	200.8	4072	
17_32709	6/14/2017	WE8 - Music	1030	LEAD	0.010	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.057	mg/L	1.3	0.005	200.8	4072	
17_32710	6/14/2017	WE9 - RM 13	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.006	mg/L	1.3	0.005	200.8	4072	
17_32711	6/14/2017	WE10 - RM 14	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.017	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Thanh B Phan at the above phone number.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
17_32712	6/14/2017	WE11 - RM 15	1030	LEAD	0.005	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.014	mg/L	1.3	0.005	200.8	4072	
17_32713	6/14/2017	WE12 - BREE2 Way	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.010	mg/L	1.3	0.005	200.8	4072	
17_32714	6/14/2017	WE13 - BREE2 Way	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.007	mg/L	1.3	0.005	200.8	4072	
17_32715	6/14/2017	WE14 - RM 16	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.008	mg/L	1.3	0.005	200.8	4072	
17_32716	6/14/2017	WE15 - RM 17	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.011	mg/L	1.3	0.005	200.8	4072	
17_32717	6/14/2017	WE16 - Gym	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.028	mg/L	1.3	0.005	200.8	4072	
17_32718	6/14/2017	WE17 - Gym	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.045	mg/L	1.3	0.005	200.8	4072	
17_32719	6/14/2017	WE18 - W. Commons	1030	LEAD	0.009	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.007	mg/L	1.3	0.005	200.8	4072	
17_32720	6/14/2017	WE19 - RM 20	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.010	mg/L	1.3	0.005	200.8	4072	
17_32721	6/14/2017	WE20 - RM 19	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.013	mg/L	1.3	0.005	200.8	4072	
17_32722	6/14/2017	WE21 - RM 18	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.011	mg/L	1.3	0.005	200.8	4072	
17_32723	6/14/2017	WE22 - N. Commons	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.018	mg/L	1.3	0.005	200.8	4072	
17_32724	6/14/2017	WE23 - Kitchen	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.022	mg/L	1.3	0.005	200.8	4072	
17_32725	6/14/2017	WE24 - Kitchen	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.015	mg/L	1.3	0.005	200.8	4072	
17_32726	6/14/2017	WE25 - Kitchen	1030	LEAD	0.399	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	1.309	mg/L	1.3	0.005	200.8	4072	
17_32727	6/14/2017	WE26 - Kitchen	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

[illegible]