



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802
Corvallis, OR Microbiology/Chemistry (d)
540 SW Third Street - Corvallis, OR 97333 - 541.753.4946
Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

Page 1 of 3

LEAD & COPPER RULE REPORT

Client Name: Woodburn School District
1390 Meridian Drive
Woodburn, OR 97071

Reference Number: **17-14172**

Project: Nellie

System Name:
System ID Number:
DWP Source Number:
Multiple Sources:
Sample Type:
Sample Purpose: Investigative or Other
County:

Analyst: bj
Date Received: 6/15/2017
Report Date: 6/26/2017
Approved By: anp
Authorized by:


Thanh B Phan
Lab Manager, Portland

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
17_32508	6/14/2017	NM-1 - Cafeteria Sink	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.105	mg/L	1.3	0.005	200.8	4072	
17_32509	6/14/2017	NM-2 - Kitchen Sprayer	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.020	mg/L	1.3	0.005	200.8	4072	
17_32510	6/14/2017	NM-3 - Kitchen Sink	1030	LEAD	0.005	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.068	mg/L	1.3	0.005	200.8	4072	
17_32511	6/14/2017	NM-4 - Kitchen Sink	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.037	mg/L	1.3	0.005	200.8	4072	
17_32512	6/14/2017	NM-5 - Kitchen Kettle	1030	LEAD	0.005	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.137	mg/L	1.3	0.005	200.8	4072	
17_32513	6/14/2017	NM-6 - Room 15	1030	LEAD	0.005	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.017	mg/L	1.3	0.005	200.8	4072	
17_32514	6/14/2017	NM-7 - Room 14	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.034	mg/L	1.3	0.005	200.8	4072	
17_32515	6/14/2017	NM-8 - Room 18	1030	LEAD	0.005	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.018	mg/L	1.3	0.005	200.8	4072	
17_32516	6/14/2017	NM-9 - Room 19	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.013	mg/L	1.3	0.005	200.8	4072	
17_32517	6/14/2017	NM-10 - Drinking Fountain	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.053	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Lawrence J Henderson at the above phone number.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
17_32518	6/14/2017	NM-11 - Drinking Fountain Short	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.061	mg/L	1.3	0.005	200.8	4072	
17_32519	6/14/2017	NM-12 - Room 7	1030	LEAD	0.010	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.011	mg/L	1.3	0.005	200.8	4072	
17_32520	6/14/2017	NM-13 - Room 12	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.016	mg/L	1.3	0.005	200.8	4072	
17_32521	6/14/2017	NM-14 - Room 13	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.034	mg/L	1.3	0.005	200.8	4072	
17_32522	6/14/2017	NM-15 - Room 11	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.049	mg/L	1.3	0.005	200.8	4072	
17_32523	6/14/2017	NM-16 - Room 10	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.026	mg/L	1.3	0.005	200.8	4072	
17_32524	6/14/2017	NM-17 - Room 9	1030	LEAD	0.006	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.009	mg/L	1.3	0.005	200.8	4072	
17_32525	6/14/2017	NM-18 - Drinking Fountain Tall	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.079	mg/L	1.3	0.005	200.8	4072	
17_32526	6/14/2017	NM-19 - Drinking Fountain Short	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.079	mg/L	1.3	0.005	200.8	4072	
17_32527	6/14/2017	NM-20 - Room 6	1030	LEAD	0.011	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.013	mg/L	1.3	0.005	200.8	4072	
17_32528	6/14/2017	NM-21 - Room 5	1030	LEAD	0.007	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.007	mg/L	1.3	0.005	200.8	4072	
17_32529	6/14/2017	NM-22 - Room 3	1030	LEAD	0.009	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.004	mg/L	1.3	0.005	200.8	4072	
17_32530	6/14/2017	NM-23 - Room 2	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.008	mg/L	1.3	0.005	200.8	4072	
17_32531	6/14/2017	NM-24 - Staff Lounge	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.022	mg/L	1.3	0.005	200.8	4072	
17_32532	6/14/2017	NM-25 - Room 17	1030	LEAD	0.007	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.012	mg/L	1.3	0.005	200.8	4072	
17_32533	6/14/2017	NM-26 - Outside Drinking Fountain	1030	LEAD	0.005	mg/L	0.015	0.001	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

LEAD & COPPER RULE REPORT

[illegible]

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL: Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.