



Burlington, WA *Corporate Laboratory (a)*
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
Bellingham, WA *Microbiology (b)*
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR *Microbiology/Chemistry (c)*
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802
Corvallis, OR *Microbiology/Chemistry (d)*
540 SW Third Street - Corvallis, OR 97333 - 541.753.4946
Bend, OR *Microbiology (e)*
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

Page 1 of 2

INORGANIC COMPOUNDS (IOC) REPORT FOR LEAD & COPPER

Client Name: Woodburn School District
1390 Meridian Drive
Woodburn, OR 97071

Reference Number: **16-15883**
Project: Washington

System Name:
System ID Number:
DWP Source Number:
Multiple Sources:
Sample Type: D - Drinking Water
Sample Purpose: C - Compliance
County:

Analyst: mvp
Date Received: 7/6/2016
Report Date: 7/20/2016
Approved By: bj
Authorized by:


Lawrence J Henderson, PhD
Director of Laboratories, Vice President

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
16_37844	7/6/2016	Room 16	1030	LEAD	0.006	mg/L	0.015	0.001	200.8	4072	
16_37845	7/6/2016	Room 17	1030	LEAD	0.006	mg/L	0.015	0.001	200.8	4072	
16_37846	7/6/2016	Outside Fountain	1030	LEAD	0.005	mg/L	0.015	0.001	200.8	4072	
16_37847	7/6/2016	Outside Fountain	1030	LEAD	0.005	mg/L	0.015	0.001	200.8	4072	
16_37848	7/6/2016	Room 15	1030	LEAD	0.005	mg/L	0.015	0.001	200.8	4072	
16_37849	7/6/2016	Room 13	1030	LEAD	0.009	mg/L	0.015	0.001	200.8	4072	
16_37850	7/6/2016	Room 14	1030	LEAD	0.007	mg/L	0.015	0.001	200.8	4072	
16_37851	7/6/2016	Music Room 21	1030	LEAD	0.008	mg/L	0.015	0.001	200.8	4072	
16_37852	7/6/2016	Room 11	1030	LEAD	0.008	mg/L	0.015	0.001	200.8	4072	
16_37853	7/6/2016	Room 12	1030	LEAD	0.007	mg/L	0.015	0.001	200.8	4072	
16_37854	7/6/2016	Hallway	1030	LEAD	0.006	mg/L	0.015	0.001	200.8	4072	
16_37855	7/6/2016	Hallway	1030	LEAD	0.005	mg/L	0.015	0.001	200.8	4072	
16_37856	7/6/2016	Room 4	1030	LEAD	0.007	mg/L	0.015	0.001	200.8	4072	
16_37857	7/6/2016	Hallway	1030	LEAD	0.006	mg/L	0.015	0.001	200.8	4072	
16_37858	7/6/2016	Room 3	1030	LEAD	0.005	mg/L	0.015	0.001	200.8	4072	
16_37859	7/6/2016	Staff Room Refer	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37860	7/6/2016	Staff Room Water Filter	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.
If you have any questions concerning this report contact Lawrence J Henderson at the above phone number.

INORGANIC COMPOUNDS (IOC) REPORT FOR LEAD & COPPER

[illegible]

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL: Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.