



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802
Corvallis, OR Microbiology/Chemistry (d)
540 SW Third Street - Corvallis, OR 97333 - 541.753.4946
Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425




Page 1 of 1

LEAD & COPPER RULE REPORT

Client Name: Woodburn School District
1390 Meridian Drive
Woodburn, OR 97071

Reference Number: **19-15383**
Project: Arthur Academy

System Name:
System ID Number:
DWP Source Number:
Multiple Sources:
Sample Type:
Sample Purpose: Investigative or Other
County:

Analyst: bj
Date Received: 5/2/2019
Report Date: 5/10/2019
Approved By: hkl
Authorized by: 

Thanh B Phan
Lab Manager, Portland

| Lab Number | Date Collected | Site / Location | EPA # | Analyte Name | Result | Units | AL | RL | METHOD | Lab | Comments |
|------------|----------------|-------------------------|-------|--------------|--------|-------|-------|-------|--------|------|----------|
| 19_30853 | 5/2/2019 | AAK1 - Arthur Academy | 1030 | LEAD | ND | mg/L | 0.015 | 0.001 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 0.066 | mg/L | 1.3 | 0.005 | 200.8 | 4072 | |
| 19_30854 | 5/2/2019 | AAHF - Arthur Academy | 1030 | LEAD | ND | mg/L | 0.015 | 0.001 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 0.179 | mg/L | 1.3 | 0.005 | 200.8 | 4072 | |
| 19_30855 | 5/2/2019 | AALF - Arthur Academy | 1030 | LEAD | ND | mg/L | 0.015 | 0.001 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 0.124 | mg/L | 1.3 | 0.005 | 200.8 | 4072 | |
| 19_30856 | 5/2/2019 | AAML - Arthur Academy | 1030 | LEAD | ND | mg/L | 0.015 | 0.001 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 0.094 | mg/L | 1.3 | 0.005 | 200.8 | 4072 | |
| 19_30857 | 5/2/2019 | AAMR - Arthur Academy | 1030 | LEAD | ND | mg/L | 0.015 | 0.001 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 0.065 | mg/L | 1.3 | 0.005 | 200.8 | 4072 | |
| 19_30858 | 5/2/2019 | AAWL - Arthur Academy | 1030 | LEAD | ND | mg/L | 0.015 | 0.001 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 0.035 | mg/L | 1.3 | 0.005 | 200.8 | 4072 | |
| 19_30859 | 5/2/2019 | AAWR - Arthur Academy | 1030 | LEAD | ND | mg/L | 0.015 | 0.001 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 0.071 | mg/L | 1.3 | 0.005 | 200.8 | 4072 | |
| 19_30860 | 5/2/2019 | AAP6F - Arthur Academy | 1030 | LEAD | ND | mg/L | 0.015 | 0.001 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 0.048 | mg/L | 1.3 | 0.005 | 200.8 | 4072 | |
| 19_30861 | 5/2/2019 | AARM2S - Arthur Academy | 1030 | LEAD | ND | mg/L | 0.015 | 0.001 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 0.132 | mg/L | 1.3 | 0.005 | 200.8 | 4072 | |
| 19_30862 | 5/2/2019 | AARM3S - Arthur Academy | 1030 | LEAD | ND | mg/L | 0.015 | 0.001 | 200.8 | 4072 | |
| | | | 1022 | COPPER | 0.149 | mg/L | 1.3 | 0.005 | 200.8 | 4072 | |
| | | | | | | | | | | | |

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Thanh B Phan at the above phone number.