



Corvallis, OR *Microbiology/Chemistry (d)*
540 SW Third Street - Corvallis, OR 97333 - 541.753.4946

LEAD & COPPER RULE REPORT

Client Name: Woodburn School District
1390 Meridian Drive
Woodburn, OR 97071

Reference Number: **17-14092**

Project: Maintenance, Success

System Name:
System ID Number:
DWP Source Number:
Multiple Sources:
Sample Type:
Sample Purpose: Investigative or Other
County:

Analyst: bj
Date Received: 6/15/2017
Report Date: 6/26/2017
Approved By: anp
Authorized by:

Champh

Thanh B Phan
Lab Manager, Portland

[illegible]

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL: Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Lawrence J Henderson at the above phone number.