



Burlington, WA Corporate Laboratory (a)  
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400  
Bellingham, WA Microbiology (b)  
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)  
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802  
Corvallis, OR Microbiology/Chemistry (d)  
540 SW Third Street - Corvallis, OR 97333 - 541.753.4946  
Bend, OR Microbiology (e)  
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



Page 1 of 3

## LEAD & COPPER RULE REPORT

Client Name: Woodburn School District  
1390 Meridian Drive  
Woodburn, OR 97071

Reference Number: **18-20515**

Project: WHS

System Name:  
System ID Number:  
DWP Source Number:  
Multiple Sources:  
Sample Type:  
Sample Purpose: Investigative or Other  
County:

Analyst: bj  
Date Received: 6/8/2018  
Report Date: 6/22/2018  
Approved By: anp  
Authorized by:

Lawrence J Henderson, PhD  
Director of Laboratories, Vice President

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_41812	6/7/2018	HS 1 - TC Restroom	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.158	mg/L	1.3	0.005	200.8	4072	
18_41813	6/7/2018	HS 2 - BF Restroom	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	ND	mg/L	1.3	0.005	200.8	4072	
18_41814	6/7/2018	HS 3 - AT Concession	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.148	mg/L	1.3	0.005	200.8	4072	
18_41815	6/7/2018	HS 4 - CIC Kitchen	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.158	mg/L	1.3	0.005	200.8	4072	
18_41816	6/7/2018	HS 5 - CIC DF	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.136	mg/L	1.3	0.005	200.8	4072	
18_41817	6/7/2018	HS 6 - Webss Office S	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.023	mg/L	1.3	0.005	200.8	4072	
18_41818	6/7/2018	HS 7 - Webss Hall L	1030	LEAD	0.005	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	ND	mg/L	1.3	0.005	200.8	4072	
18_41819	6/7/2018	HS 8 - Webss Hall R	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	ND	mg/L	1.3	0.005	200.8	4072	
18_41820	6/7/2018	HS 9 - Large Commons Left	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.082	mg/L	1.3	0.005	200.8	4072	
18_41821	6/7/2018	HS 10 - Large Commons Right	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.073	mg/L	1.3	0.005	200.8	4072	

### NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Thanh B Phan at the above phone number.

## LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_41822	6/7/2018	HS 11 - East Commons Left	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.073	mg/L	1.3	0.005	200.8	4072	
18_41823	6/7/2018	HS 12 - East Commons Right	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.070	mg/L	1.3	0.005	200.8	4072	
18_41824	6/7/2018	HS 13 - K Sink 1	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.153	mg/L	1.3	0.005	200.8	4072	
18_41825	6/7/2018	HS 14 - K Kettle	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.129	mg/L	1.3	0.005	200.8	4072	
18_41826	6/7/2018	HS 15 - K Sink 2	1030	LEAD	0.016	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.048	mg/L	1.3	0.005	200.8	4072	
18_41827	6/7/2018	HS 16 - K Sink 3	1030	LEAD	0.044	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.041	mg/L	1.3	0.005	200.8	4072	
18_41828	6/7/2018	HS 17 - K Dishwasher	1030	LEAD	0.008	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.029	mg/L	1.3	0.005	200.8	4072	
18_41829	6/7/2018	HS 18 - K Sink 4	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.043	mg/L	1.3	0.005	200.8	4072	
18_41830	6/7/2018	HS 19 - Gym H L	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.128	mg/L	1.3	0.005	200.8	4072	
18_41831	6/7/2018	HS 20 - Gym H R	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.122	mg/L	1.3	0.005	200.8	4072	
18_41832	6/7/2018	HS 21 - L Gym Ice Machine	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.006	mg/L	1.3	0.005	200.8	4072	
18_41833	6/7/2018	HS 22 - Work Room Right	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.047	mg/L	1.3	0.005	200.8	4072	
18_41834	6/7/2018	HS 23 - Work Room Left	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.172	mg/L	1.3	0.005	200.8	4072	
18_41835	6/7/2018	HS 24 - Waast Copy Room	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.172	mg/L	1.3	0.005	200.8	4072	
18_41836	6/7/2018	HS 25 - Lectorium Left	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.172	mg/L	1.3	0.005	200.8	4072	
18_41837	6/7/2018	HS 26 - Lectorium Right	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	

### NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

**These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.**

## LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_41837	6/7/2018	HS 26 - Lectorm Right	1022	COPPER	0.175	mg/L	1.3	0.005	200.8	4072	
18_41838	6/7/2018	HS 27 - S Gym Ice Machine	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.063	mg/L	1.3	0.005	200.8	4072	
18_41839	6/7/2018	HS 28 - Waca Staff Room	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.154	mg/L	1.3	0.005	200.8	4072	
18_41840	6/7/2018	HS 29 - Ais Short Hall Left	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.070	mg/L	1.3	0.005	200.8	4072	
18_41841	6/7/2018	HS 30 - Ais Short Hall Right	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.073	mg/L	1.3	0.005	200.8	4072	
18_41842	6/7/2018	HS 31 - Ais LH Left	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.037	mg/L	1.3	0.005	200.8	4072	
18_41843	6/7/2018	HS 32 - Ais LH Right	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.040	mg/L	1.3	0.005	200.8	4072	
18_41844	6/7/2018	HS 33 - Ais Staff Lounge	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.052	mg/L	1.3	0.005	200.8	4072	
18_41845	6/7/2018	HS 34 - Ais End Left	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.076	mg/L	1.3	0.005	200.8	4072	
18_41846	6/7/2018	HS 35 - Ais End Right	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.080	mg/L	1.3	0.005	200.8	4072	
18_41847	6/7/2018	HS 36 - Chior Room	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.042	mg/L	1.3	0.005	200.8	4072	

### NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

**These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.**