



Burlington, WA Corporate Laboratory (a)  
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)  
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)  
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)  
540 SW Third Street - Corvallis, OR 97333 - 541.753.4946

Bend, OR Microbiology (e)  
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

## LEAD & COPPER RULE REPORT

Client Name: Woodburn School District  
1390 Meridian Drive  
Woodburn, OR 97071

Reference Number: **17-14190**

Project: Lincoln

System Name:  
System ID Number:  
DWP Source Number:  
Multiple Sources:  
Sample Type:  
Sample Purpose: Investigative or Other  
County:

Analyst: bj  
Date Received: 6/15/2017  
Report Date: 6/26/2017  
Approved By: anp  
Authorized by:

  
Thanh B Phan  
Lab Manager, Portland

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
17_32637	6/14/2017	L-1 - Gym w/ Drinking Fountain	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.036	mg/L	1.3	0.005	200.8	4072	
17_32638	6/14/2017	L-2 - Room # 42 DWF	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.191	mg/L	1.3	0.005	200.8	4072	
17_32639	6/14/2017	L-3 - Room # 1 DWF	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.229	mg/L	1.3	0.005	200.8	4072	
17_32640	6/14/2017	L-4 - Room # 2 DWF	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.120	mg/L	1.3	0.005	200.8	4072	
17_32641	6/14/2017	L-5 - Front Hallway DWF	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.013	mg/L	1.3	0.005	200.8	4072	
17_32642	6/14/2017	L-6 - Room # 6 DWF	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.165	mg/L	1.3	0.005	200.8	4072	
17_32643	6/14/2017	L-7 - Room # 10 DWF	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.118	mg/L	1.3	0.005	200.8	4072	
17_32644	6/14/2017	L-8 - Room # 14 DWF	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.150	mg/L	1.3	0.005	200.8	4072	
17_32645	6/14/2017	L-9 - Room # 16 DWF	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.064	mg/L	1.3	0.005	200.8	4072	
17_32646	6/14/2017	L-10 - Room # 18 DWF	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.154	mg/L	1.3	0.005	200.8	4072	

### NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Thanh B Phan at the above phone number.

## LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
17_32647	6/14/2017	L-11 - N. Hallway DWF	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.052	mg/L	1.3	0.005	200.8	4072	
17_32648	6/14/2017	L-12 - Room # 19 DWF	1030	LEAD	0.006	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.338	mg/L	1.3	0.005	200.8	4072	
17_32649	6/14/2017	L-13 - Room # 20 DWF	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.164	mg/L	1.3	0.005	200.8	4072	
17_32650	6/14/2017	L-14 - Room # 17 DWF	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.183	mg/L	1.3	0.005	200.8	4072	
17_32651	6/14/2017	L-15 - Room # 15 DWF	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.176	mg/L	1.3	0.005	200.8	4072	
17_32652	6/14/2017	L-16 - Room # 16 DWF	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.134	mg/L	1.3	0.005	200.8	4072	
17_32653	6/14/2017	L-17 - Room # 17 DWF	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.147	mg/L	1.3	0.005	200.8	4072	
17_32654	6/14/2017	L-18 - Back Hallway 18 DWF	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.108	mg/L	1.3	0.005	200.8	4072	
17_32655	6/14/2017	L-19 - Back Hallway 19 DWF	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.109	mg/L	1.3	0.005	200.8	4072	
17_32656	6/14/2017	L-20 - Staff Room # 33 DWF	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.170	mg/L	1.3	0.005	200.8	4072	
17_32657	6/14/2017	L-21 - Kitchen	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.212	mg/L	1.3	0.005	200.8	4072	
17_32658	6/14/2017	L-22 - Kitchen	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.180	mg/L	1.3	0.005	200.8	4072	
17_32659	6/14/2017	L-23 - Kitchen	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.303	mg/L	1.3	0.005	200.8	4072	
17_32660	6/14/2017	L-24 - Kitchen	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.098	mg/L	1.3	0.005	200.8	4072	
17_32661	6/14/2017	L-25 - Kitchen	1030	LEAD	0.020	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.082	mg/L	1.3	0.005	200.8	4072	
17_32662	6/14/2017	L-26 - Kitchen	1030	LEAD	0.019	mg/L	0.015	0.001	200.8	4072	

**NOTES:**

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.

## LEAD & COPPER RULE REPORT

[illegible]

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL: Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.