



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802
Corvallis, OR Microbiology/Chemistry (d)
540 SW Third Street - Corvallis, OR 97333 - 541.753.4946
Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



Page 1 of 2

LEAD & COPPER RULE REPORT

Client Name: Woodburn School District
1390 Meridian Drive
Woodburn, OR 97071

Reference Number: **18-20431**

Project: Nellie Muir

System Name:
System ID Number:
DWP Source Number:
Multiple Sources:
Sample Type:
Sample Purpose: Investigative or Other
County:

Analyst: bj
Date Received: 6/8/2018
Report Date: 6/22/2018
Approved By: anp
Authorized by:

Lawrence J Henderson, PhD
Director of Laboratories, Vice President

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_41621	6/6/2018	Nellie-1 - Cafeteria Sink	1030	LEAD	0.005	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.017	mg/L	1.3	0.005	200.8	4072	
18_41622	6/6/2018	Nellie-2 - Kitchen Sprayer	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.012	mg/L	1.3	0.005	200.8	4072	
18_41623	6/6/2018	Nellie-3 - Kitchen Sink 1	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.010	mg/L	1.3	0.005	200.8	4072	
18_41624	6/6/2018	Nellie-4 - Kitchen Sink 2	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.011	mg/L	1.3	0.005	200.8	4072	
18_41625	6/6/2018	Nellie-5 - Room-15	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.008	mg/L	1.3	0.005	200.8	4072	
18_41626	6/6/2018	Nellie-6 - Room-14	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.014	mg/L	1.3	0.005	200.8	4072	
18_41627	6/6/2018	Nellie-7 - Room-18	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.009	mg/L	1.3	0.005	200.8	4072	
18_41628	6/6/2018	Nellie-8 - Room-19	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.008	mg/L	1.3	0.005	200.8	4072	
18_41629	6/6/2018	Nellie-9 - Drinking Fountain	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.040	mg/L	1.3	0.005	200.8	4072	
18_41630	6/6/2018	Nellie-10 - Drinking Fountain Short	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.045	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Thanh B Phan at the above phone number.

LEAD & COPPER RULE REPORT

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_41631	6/6/2018	Nellie-11 - Room-7	1030	LEAD	0.006	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.012	mg/L	1.3	0.005	200.8	4072	
18_41632	6/6/2018	Nellie-12 - Room-12	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.009	mg/L	1.3	0.005	200.8	4072	
18_41633	6/6/2018	Nellie-13 - Room-13	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.024	mg/L	1.3	0.005	200.8	4072	
18_41634	6/6/2018	Nellie-14 - Room-11	1030	LEAD	0.005	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.024	mg/L	1.3	0.005	200.8	4072	
18_41635	6/6/2018	Nellie-15 - Room-10	1030	LEAD	0.006	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.028	mg/L	1.3	0.005	200.8	4072	
18_41636	6/6/2018	Nellie-16 - Room-9	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.014	mg/L	1.3	0.005	200.8	4072	
18_41637	6/6/2018	Nellie-17 - Fountain Tall	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.047	mg/L	1.3	0.005	200.8	4072	
18_41638	6/6/2018	Nellie-18 - Fountain Short	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.051	mg/L	1.3	0.005	200.8	4072	
18_41639	6/6/2018	Nellie-19 - Room-6	1030	LEAD	0.011	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.013	mg/L	1.3	0.005	200.8	4072	
18_41640	6/6/2018	Nellie-20 - Room-5	1030	LEAD	0.008	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.005	mg/L	1.3	0.005	200.8	4072	
18_41641	6/6/2018	Nellie-21 - Room-3	1030	LEAD	0.008	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	ND	mg/L	1.3	0.005	200.8	4072	
18_41642	6/6/2018	Nellie-22 - Room-2	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.007	mg/L	1.3	0.005	200.8	4072	
18_41643	6/6/2018	Nellie-23 - Staff Lounge	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.013	mg/L	1.3	0.005	200.8	4072	
18_41644	6/6/2018	Nellie-24 - Room-17	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.009	mg/L	1.3	0.005	200.8	4072	
18_41645	6/6/2018	Nellie-25 - Outside Fountain	1030	LEAD	0.006	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	ND	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.