



Burlington, WA Corporate Laboratory (a)  
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400  
Bellingham, WA Microbiology (b)  
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)  
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802  
Corvallis, OR Microbiology/Chemistry (d)  
540 SW Third Street - Corvallis, OR 97333 - 541.753.4946  
Bend, OR Microbiology (e)  
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



Page 1 of 1

## LEAD & COPPER RULE REPORT

Client Name: Woodburn School District  
1390 Meridian Drive  
Woodburn, OR 97071

Reference Number: **18-20387**

Project: Aztec Maint, Ciprino, Its,  
District Office

System Name:  
System ID Number:  
DWP Source Number:  
Multiple Sources:  
Sample Type:  
Sample Purpose: Investigative or Other  
County:

Analyst: bj  
Date Received: 6/8/2018  
Report Date: 6/22/2018  
Approved By: anp  
Authorized by:

Lawrence J Henderson, PhD  
Director of Laboratories, Vice President

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
18_41480	6/8/2018	Main 1 - Outside F	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.041	mg/L	1.3	0.005	200.8	4072	
18_41481	6/8/2018	Main 2 - Break Rm Sink	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.085	mg/L	1.3	0.005	200.8	4072	
18_41482	6/8/2018	AZ-2 - Drinking Fountain	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.262	mg/L	1.3	0.005	200.8	4072	
18_41483	6/8/2018	Ci-1 - Prep Sink	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.128	mg/L	1.3	0.005	200.8	4072	
18_41484	6/8/2018	Ci-2 - Dish Sink	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.095	mg/L	1.3	0.005	200.8	4072	
18_41485	6/8/2018	DO-1 - Tall Foun	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.101	mg/L	1.3	0.005	200.8	4072	
18_41486	6/8/2018	DO-2 - Short Foun	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.109	mg/L	1.3	0.005	200.8	4072	
18_41487	6/8/2018	DO-3 - Break Rm	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.072	mg/L	1.3	0.005	200.8	4072	
18_41488	6/8/2018	AZ-1 - Kitchen Sink	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.260	mg/L	1.3	0.005	200.8	4072	

### NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.  
If you have any questions concerning this report contact Thanh B Phan at the above phone number.