



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)
540 SW Third Street - Corvallis, OR 97333 - 541.753.4946

Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

LEAD & COPPER RULE REPORT

Client Name: Woodburn School District
1390 Meridian Drive
Woodburn, OR 97071

Reference Number: **17-14094**

Project: FP

System Name:
System ID Number:
DWP Source Number:
Multiple Sources:
Sample Type:
Sample Purpose: Investigative or Other
County:

Analyst: bj
Date Received: 6/15/2017
Report Date: 6/26/2017
Approved By: anp
Authorized by:


Thanh B Phan
Lab Manager, Portland

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
17_32324	6/15/2017	Fou 1 - Common's	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.218	mg/L	1.3	0.005	200.8	4072	
17_32325	6/15/2017	F 2 - Hall A	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.059	mg/L	1.3	0.005	200.8	4072	
17_32326	6/15/2017	F 3 - Hall A	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.058	mg/L	1.3	0.005	200.8	4072	
17_32327	6/15/2017	F 4 - Hall A	1030	LEAD	0.007	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.025	mg/L	1.3	0.005	200.8	4072	
17_32328	6/15/2017	F 5 - Hall B	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.056	mg/L	1.3	0.005	200.8	4072	
17_32329	6/15/2017	F 6 - Hall B	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.051	mg/L	1.3	0.005	200.8	4072	
17_32330	6/15/2017	F 7 - Gym	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.027	mg/L	1.3	0.005	200.8	4072	
17_32331	6/15/2017	F 8 - Gym	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.020	mg/L	1.3	0.005	200.8	4072	
17_32332	6/15/2017	F 9 - Gym	1030	LEAD	0.006	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.009	mg/L	1.3	0.005	200.8	4072	
17_32333	6/15/2017	F 10 - Gym	1030	LEAD	0.005	mg/L	0.015	0.001	200.8	4072	
			1022	COPPER	0.016	mg/L	1.3	0.005	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Lawrence J Henderson at the above phone number.

LEAD & COPPER RULE REPORT

[illegible]

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL: Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.